

EC-Certificate of Conformity

In compliance with the Directive 89/106/EEC of the Council of European communities of 21 December 1988 on the approximation of laws, regulations and administrative provisions of the Member States relating to the construction products (Construction Products Directive – CPD), amended by the Directive 93/68/EEC of the Council of European Communities of 22 July 1993, and implemented in Swedish law by BVL, it has been stated that the construction product

Träullit – Akustik normal

Designation code: WW – EN 13168 – CS(10)300 – C13

Thermal insulation WW for use in construction works. The product exists in two versions unpainted and painted. The product has a nominal area weight of 13 kg/m² and a nominal thickness of 30 mm.

Thermal conductivity λ_D 0,080 W/(m.K)

Compatibility with other materials (chloride content) < 0,02 %

Compressive strength (CS10/Y) 300 kPa

Fire classification B – s1, d0

placed on the market by

Träullit AB

Drottninggatan 92, SE-252 21 HELSINGBORG, Sweden

and produced in the factory located at

ÖSTERBYMO, Sweden

is submitted by the manufacturer to a factory production control and to the further testing of samples taken at the factory in accordance with a prescribed test plan and that the notified body

SP Swedish National Testing and Research Institute

has performed the initial type-testing for the relevant characteristics of the product, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment and approval of the factory production control.

This certificate attests that all provisions concerning the attestation of conformity and the performances described in Annex ZA of the standard EN 13168:2001 and PrA1:2004 were applied and that the product fulfils all the prescribed requirements.


This certificate was first issued on 4th October 2005 and remains valid as long as the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory production and the FPC itself are not modified significantly or at the latest until 31 October 2010

Borås 4th October 2005

**SP Swedish National Testing and Research Institute
Certification**



Lennart Månsson
Certification Manager



Ingvar Sahlin
Certification Officer

EC Certificate of Conformity issued by Notified Body No. 0402



SP Swedish National Testing and Research Institute

Postal address	Phone / Fax	Reg. number	E-mail / Internet
SP	+46 33-16 50 00	556464-6874	info@sp.se
Box 857	+46 33-13 55 02		www.sp.se
SE-501 15 Borås			
SWEDEN			

Swedish Notified Bodies are appointed by SWEDAC, the Swedish Board for Accreditation and Conformity Assessment, under the terms of Swedish legislation.
This certificate may not be reproduced other than in full, except with the prior written approval by SP.